



1. A valve box top section shall be used as a curb box cover whenever the curb box falls into new or replaced concrete sidewalk, drive approach, or bituminous pavement areas.
- ② Valve box top section shall be of the screw type, have a minimum inside shaft diameter of 5 1/4", and have a cap with the word "water" plainly marked on top.
3. In all respects the valve box shall be equal to Tyler/Union-10T-UCP#144939.
4. Valve box cover shall be of the locking type, equal to a Tyler/Union UPC#145462.
- ⑤ Curb box riser cap is to be a minimum of 4" and a maximum of 6" below the finished pavement grade.